

**GOVERNMENT OF WEST BENGAL**  
**OFFICE OF THE DIVISIONAL FIRE OFFICER**  
**WEST BENGAL FIRE & EMERGENCY SERVICES**  
**L.M. Dey Garden, D. H. Road, Silpara, Pin – 700008**

Memo No : IND/WB/FES/20222023/20154

DATE: 10/05/2022

**From :**

**The Divisional Fire Officer**  
**Fire Prevention Wing,**  
**West Bengal Fire & Emergency Services.**

**To :**

**DELHI PUBLIC HIGH SCHOOL KNOWLEDGE CITY**  
**KNOWLEDGE CITY, D. H. ROAD, HAYATNAGAR RAJARHAT,**  
**SHIRAKOLE, 24 PGS (S)**  
**Diamond Harbour F.S., Diamond Harbour,**  
**South 24 Parganas – 743513.**

**Sub :Fire Safety Certificate for the occupancy of an existing construction of G + II storied under group Institutional building at the premises no.- KNOWLEDGE CITY, D. H. ROAD, HAYATNAGAR RAJARHAT, SHIRAKOLE, Diamond Harbour, South 24 Parganas, pin – 743513.**

This is in reference to your Application No. IND/WB/FES/2022-2023/20154, dated 10/05/2022, regarding the Fire Safety Certificate for the occupancy of an existing construction of G + II storied under group Institutional building at the premises no.- KNOWLEDGE CITY, D. H. ROAD, HAYATNAGAR RAJARHAT, SHIRAKOLE, Diamond Harbour, South 24 Parganas, pin – 743513..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

- 1.1.Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the driveway.
- 2.The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.
- 3.To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.

- 4.Existing electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling.
- 5.The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
- 6.The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate in the event of Fire and testing.
- 7.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 8.Electrical switch gear room shall be protected with automatic CO2 or D.C.P. Fire extinguisher confirming I.S. specification.
- 9.First aid Fire fighting system shall be provided as per I.S. specification.
- 10.Arrangement shall have to be made for regular checking, testing and maintenance of all the Firefighting installation in the building to keep them in perfectly good working condition at all the times.
- 11.If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.
- 12Periodical flashing of water from the fire water pipe line shall made to maintain efficient working performance of above mentioned system.
- 13.This F.S.C. is valid for 01(one) year and have to be renewed every year from the date of issue of this letter.
- 14.Each year a certificate is to be obtained from the Divisional Fire Officer, West Bengal Fire & Emergency Services, for performances of all the Life and Fire Safety arrangements and installation of the building.

**Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**

Signature valid  
Digitally signed by TUSHAR  
KANTI SEN  
Date: 2022.05.10 16:34:50 IST